



**THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD.**

**JANPATH, BHOI NAGAR, BHUBANESWAR-22.**

**Tel: 0674-2541545, 2542921, Fax: 0674-2541543,**

**E-mail: [jmelectricalophwc@gmail.com](mailto:jmelectricalophwc@gmail.com), Web: [www.ophwc.nic.in](http://www.ophwc.nic.in)**

**SHORT TENDER CALL NOTICE NO : 13/JM/ELECT/OPHWC/2019-20**

**2<sup>ND</sup> CORRIGENDUM**

In continuation to the Pre-Qualification Notice No:-13/JM/ELECT/OPHWC/2019-20 uploaded in the Website: [www.ophwc.nic.in](http://www.ophwc.nic.in) of this office & corrigendum issued on 11.09.2019 the following 2<sup>nd</sup> corrigendum is being issued on the items as stated below. All other terms & conditions remain unchanged.

**Additional clause to be incorporated in the technical specification for PCU**

1. There should be provision to charge the battery using Grid power as long as grid voltage is between 170V-265V. In case Grid voltage falls below 170V up to 130V, Grid charging shall stop but load shall continue to run using Grid supply not by Solar. In case of three phase system, phase to neutral voltage shall be in this range for all three phase.
2. There should be provision to export excess PV power to grid in case the load consumption is less than actual generation only for the plants having capacity equal to and more than 5 KW. This is futuristic feature and provision should be there to enable or disable this export feature.

**Sd/-  
Joint Manager (Elect.)**