

**THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD.**  
**JANPATH, BHUBANESWAR-22.**  
Tel: 0674 2541545; Fax: 0674 2541543; E-mail :policehousing@rediffmail.com  
web : ophwc.nic.in

**CORRIGENDUM AND TIME EXTENSION NOTICE**  
**BID REFERENCE NO: - 10 / 2013-14 /ELECT/ OSPH&WC**

1. Clause 3(d) of the General Conditions of the Contract ( GCC) should read as follows.  
“The bidder must be a profit making company registered under the Indian Companies Act or its agent *who also must be an Indian entity* and specifically authorized to bid for this tender. The bidder must have a local office and service center in Odisha along with adequate trained manpower.”
2. Clause 3(i) of the General Conditions of the Contract ( GCC) should read as follows.  
“The bidder, if not a manufacturer of the entire high mast lighting system being offered by it , must submit undertakings from the manufacturer of the systems and sub systems of the offered high mast light system that they will provide warranty and service back up to the system on site for **5 years** from the date of installation. The authorization must clearly mention the presence of service facilities & man power in Odisha. The authorization must clearly confirm support to the bidder for design, installation and maintenance work for the bid being submitted by it. **If the bidder is bidding on the basis of an authorization from a Principal then the entire requirements of this clause must be met by the Principal who has authorized the bidder. All authorizations, undertakings and other relevant communications from the Principal under this clause must be signed by a representative of the manufacturer authorized to do so. The copy of the said authorization must be enclosed along with the bid documents. If such authorization is not available, the person signing such document may submit an Affidavit executed in front of a Magistrate in support of his eligibility to sign such documents and the bidder must countersign it as witness to the Affidavit.**”
3. Clause 42 of the General Conditions of the Contract ( GCC) should be read as follows.  
“Light mast shall be as per the specification sheet attached. Structural calculation of high mast and light carriages conforming to the relevant specifications mentioned in page 26 of the GCC along with the foundation drawing must be submitted. Design approval for the mentioned items must be obtained from a national level government test laboratory of repute authorized to issue such approvals. Soil Bearing capacity of **5 T/Sq. Mtr** and maximum wind speed of 250 km per hour should be taken into considered for the purpose.”
4. Clause 43 of the General Conditions of the Contract ( GCC) should be read as follows.  
“The design of the foundation for the Light Mast must be submitted to the undersigned for approval. Approval must be obtained in writing about the acceptability of the design before

starting the erection work. Type Test certificate of winch and the lantern carriage approved by a national level government test laboratory of repute authorized to issue such approvals should be attached with the bid.”

5. The content in the row marked **A** in the table on **page 26** under the heading **TITLE** should be read as **Wind Loading** in place of **AISI 316 IS: 2266**.
6. The diameter of the lantern carriage mentioned on **page 25** is indicative. The bidder should offer a carriage with diameter which is appropriate for the mast offered.

Sd/-  
**Chief Engineer.**