

**THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD.
JANPATH, BHUBANESWAR-22.**

Tel: 0674 2541545; Fax: 0674 2541543; E-mail : jmelectricalophwc@gmail.com

Web: ophwc.nic.in

BID REFERENCE NO: - 2/ 2015-16/ELECT/ OPHWC

**SCHEDULE OF TENDER FOR INTERNAL ELECTRIFICATION WORK OF SUB –
JAIL,BANPUR IN THE DIST. OF KHURDA.**

SOLD TO : M/S _____

MONEY

RECEIPT NO : _____

DATE : _____

[SIGNATURE OF ISSUING OFFICER]

THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD.
JANPATH, BHUBANESWAR-22.
Tel: 0674 2541545; Fax: 0674 2541543; E-mail : jmelectricalophwc@gmail.com
Web: ophwc.nic.in

TENDER CALL NOTICE
BID REFERENCE NO: - 02/ 2015-16/ELECT/ OPHWC

1. Sealed tender in the prescribed form with detailed Tender Call Notice for execution of external electrification, internal electrification, Area illumination and Generator wiring works of different projects are invited in single cover system from the enlisted H.T. / M.V.(M.V. Contractors only participated with internal electrification work, Area illumination works and Generator wiring) electrical contractors/Firms under O.S.P.H&W.C., Bhubaneswar including supply of materials as per the specification. Tender to be submitted separately for each project.

Sl.No	Name of the Project	Estimated Cost	EMD	Cost of tender paper including vat	Period of completion	Eligibility Range
1	Internal Electrification work of Regional Probation Office at Berhampur in the Dist. of Ganjam.	Rs. 2,67,135.00	Rs.2,671.00	Rs.2,100.00	45 days	Up to 10 lakh & above
2	External electrification work of Sub – Jail,Gunupur in the Dist. of Rayagada.	Rs. 4,77,641.00	Rs.4,776.00	Rs.2,100.00	45 days	Up to 10 lakh & above
3	Internal Electrification work of Sub – Jail,Karanja in the Dist. of Mayurbhanj.	Rs. 11,10,785.00	Rs.11,108.00	Rs.6,300.00	45 days	10 lakh above
4	Internal Electrification work of Sub – Jail,Nilagiri in the Dist. of Balasore.	Rs.8,54,095.00	Rs.8,541.00	Rs.4,200.00	45 days	Upto 10 lakh & above
5	Internal Electrification work of Sub – Jail,Kuchinda in the Dist. of Sambalpur.	Rs. 12,77,200.00	Rs.12,772.00	Rs.6,300.00	45 days	10 lakh above
6	Internal Electrification work of Sub –	Rs. 11,40,149.00	Rs.11,401.00	Rs.6,300.00	45 days	10 lakh above

	Jail,Banpur in the Dist. of Khurda.					
7	Generator Wiring at Dhenkanal Dist. Jail in the Dist. of Dhenkanal.	Rs. 3,75,700.00	Rs.3,757.00	Rs.2,100.00	45 days	Up to 10 lakh & above
8	Peripheral lighting system at outside the Jail Premises of Spl. Jail,Rourkela in the Dist. of Sundergarh.	Rs. 3,89,496.00	Rs.3,895.00	Rs.2,100.00	45 days	Up to 10 lakh & above
9	Area illumination Work at Circle Jail,Baripada in the Dist. of Mayurbhanj.	Rs. 15,06,750.00	Rs.15,068.00	Rs.6,300.00	45 days	10 lakh above
10	Restoration of External Electrification work and Area illumination work of Sub-Jail, Kodala damaged due to cuclonic storm ' Philin' 2013.	Rs.3,24,327.00	Rs.3,243.00	Rs.2,100.00	45 days	Up to 10 lakh & above
11	Area illumination Work of 100 Men Barrack Pre-Engineered Structure at Gazalbadi in the Dist. of Ganjam.	Rs. 4,31,832.00	Rs. 4,318.00	Rs.2,100.00	45 days	Up to 10 lakh & above
12	Area illumination work of Model Police Station at Digapahandi in the Dist. of Ganjam.	Rs. 3,77,006.00	Rs.3,770.00	Rs.2,100.00	45 days	Up to 10 lakh & above
13	External electrification work of BSF Camp at Gamphakonda in the dist. of Malkangiri.	Rs. 5,49,196.00	Rs.5,492.00	Rs.4,200.00	45 days	Up to 10 lakh & above
14	External electrification work of New Fire Station Building at Saranagada in the Dist. of Kandhamal.	Rs.5,76,770.00	Rs.5,768.00	Rs.4,200.00	45 days	Upto 10 lakh & above
15	Area illumination work of 100 Men Barrack at Reserve Office,Phulbani in the Dist. of kandhamal.	Rs. 2,78,585.00	Rs.2,786.00	Rs.2,100.00	45 days	Up to 10 lakh & above
16	External electrification work of 100 Men barrack at Reserve Office Phulbani in the	Rs. 6,50,236.00	Rs.6,502.00	Rs.4,200.00	45 days	Up to 10 lakh & above

	Dist. of Kandhamal.					
17	Addl. External electrification work of Gopalpur Out Post in the Dist. of Balasore .	Rs. 5,47,214.00	Rs.5,472.00	Rs.4,200.00	45 days	Up to 10 lakh & above

2. The tender document may be obtained on payment of the tender paper cost as mentioned in the Column – 5 of the above table [Non refundable] for each project between 10.00 A.M. to 05.00 P.M on each working day from the office of the undersigned at the Address given above of O.S.P.H.&WC at Bhubaneswar on or before Dt.30.05.2015 .Tender document can also be obtained through speed post by sending a self addressed envelope of size 35 cm x 25 cm along with a Demand Draft / Pay Order of the tender paper cost as mentioned in the Column – 5 of the above table and Rs. 200.00 (Rupees two hundred only) extra for purchased by post[Non refundable] for each project on any scheduled Bank, payable at Bhubaneswar, drawn in favour of the **“The Odisha State Police Housing &Welfare corporation Ltd.”**. However, such request must be received by the undersigned on or before the last date for issue of tender document. The O.S.P.H.&W.C. authorities shall not be responsible for postal or other delays. The tender document will also be available from the web site www.ophwc.nic.in and the same can be downloaded to be used for tender offer. However in case of downloaded tender documents an amount of the tender paper cost as mentioned in the Column – 5 of the above table [Non refundable] for each project in shape of Demand Draft / Pay Order drawn on any scheduled Bank, is payable at Bhubaneswar in favour of the **“The Odisha State Police Housing & Welfare Corporation Ltd.”** along with the tender , failing which tender shall be liable for rejection.
- 3.The bidders are requested to submit the receipt of showing cost of tender paper along with the attested copies of valid H.T./MV license from ELBO, Income tax return copy, PAN card, TIN No, up to date VAT clearance certificate along with bid documents otherwise the bid shall be liable for rejection.
4. **EMD** - The tender shall be accompanied with EMD as mentioned above in shape of D.D. / Pay order drawn on any Nationalized Bank in favour of the **“The Odisha State Police Housing &Welfare corporation Ltd.”**, failing which the tender shall be rejected.
5. Other details can be seen in the tender documents.
6. Bids submitted otherwise than in the manner prescribed in the tender document shall be rejected.

7. The bidding document should be super scribed “Tender for external electrification works, Tender No., Name of the Project etc.” / “Tender for internal electrification work, Tender No., Name of the Project etc.”/ “Tender for area illumination works, Tender No., Name of the Project etc.”/ “Tender for Generator wiring, Tender No., Name of the Project etc.”
8. The tender document is available from :10 AM on Dt.20.05.2015
9. Last date for issue of tender document is up to : 05.00 PM on Dt.30.05.2015
10. Last date for receipt of tender document is up to : 12.30 PM on Dt.05.06.2015
11. Date of opening of bid at : 03.30 PM on Dt.05.06.2015
12. The authority reserves the right to reject any or all the bids without assigning any reason thereof.
13. An affidavit is to be furnish by the bidder at the time of submitting bid document that he is not blacklisted / defaulter contractor or Firm etc. The authority reserves the right to reject any or all the bids without assigning any reason thereof and can impose any conditions as deemed proper before finalisation of tender.

Sd/-
Joint Manager (Elect.)

GENERAL CONDITION OF THE CONTRACT
BID REFERENCE NO: - 02 / 2015-16 /ELECT/ OPHWC

1. The tender document shall be accompany with the EMD as above only in shape of Demand Draft / Pay Order drawn on any Nationalized Bank payable at Bhubaneswar in favour of the “**The Odisha State Police Housing & Welfare Corporation Ltd.**” failing which the tender shall be rejected.
2. The bidders are requested to submit the receipt of showing cost of tender paper along with the attested copies of valid H.T. license from ELBO, Income tax return copy, PAN card, TIN No, upto date VAT clearance certificate and VAT registration certificate along with bid documents otherwise the bid shall be liable for rejection. The latest authenticated documentary proof shall be submitted. The proof submitted earlier in some other contest shall not be treated as valid and sufficient.
3. The bid must accompany proof of executing same nature of work as per eligibility criteria mentioned in tender call notice in Govt. / Govt. Undertaking. Departments. The copy of work order and completion certificates in support of credential should be enclosed with the tender otherwise the bid shall be rejected.
4. The bidding document should be super scribed “Tender for external electrification works, Tender No., Name of the Project etc.” / “Tender for internal electrification work, Tender No., Name of the Project etc.”/ “Tender for area illumination works, Tender No., Name of the Project etc.”/ “Tender for Generator wiring, Tender No., Name of the Project etc.”
5. The tenders (also called bids) not submitted in prescribed format or in prescribed manner, shall be rejected at the risk and responsibility of bidder.
6. All the information as called for in the tender document should be submitted truly, clearly, legible, transparently, unambiguously and without the use of abbreviations. It shall be submitted in English only.
7. All the crucial figures, like rates and amount should be written in figures followed by words in a bracket.
8. There shall be no over writing in the tender document and other papers submitted. All additions, alternations, deletions and cutting should be initialed with rubber-stamp (or seal) by the same person, who signs the tender document, failing which so, the tender may be rejected.

9. All the rates and amounts shall be quoted in Indian Rupee and shall be presumed to be in Indian Rupee only unless specifically permitted to be quoted otherwise in this tender document.
10. Each page of this tender document should be signed by the bidder with seal in token of having read, understood and accepted the terms and conditions of this contract.
11. Use separate piece of paper where the space provided in the formats in this tender document for submission of information is not sufficient.
12. The contractor shall stand for guarantee against defective materials / manufacturing defects(except lamp in case of Area illumination work) and workmanship for the work carried out by him for a period of **24** months from its commissioning /handing over & make good /repair/replace the faults during this period without any extra cost, failing which the same shall be got done at the risk and cost of the contractor. The work shall be supervised by the qualified supervisor from the contractor's side.
13. All information submitted or supplied in the formats of this tender document shall be presumed to be true to the best of knowledge of bidder.
14. The firms not having VAT Registration certificate shall not be eligible for submitting the bids. The blacklisted firms shall also not be eligible for participating in the bid.
15. The tenders/bids can be sent by post or courier as well. However, authorities shall not be responsible for postal or delays in receipt of bids.
16. If the last date for receipt of the tender/bid turns out to be a holiday, it will automatically be extended to next working day.
17. A bid submitted can not be withdrawn. The bidder or his authorized representative (one person only) will be allowed to be present at the time of opening of tenders. They will not participate in the discussions. Clarification sought, if any may be provided by them.
18. All or any of the tenders /bids submitted can be rejected without assigning any reason thereof. No claim, whatsoever, shall be admissible for the alleged loss/damages suffered by bidders on account of such rejections.
19. Bids shall be opened in the presence of the bidders or their authorized representative.
20. Prices quoted for each item shall be inclusive of all i.e. taxes and duties, excise duty, service taxes, loading, unloading, transportation, insurance, watch and ward etc.
21. Advance payment /part payment will not be entertained before completion and handing over the work.
22. No claim can be made due to some unforeseen delay for release of payment.

23. Payment of bill will be made only after completion of the work in all respects i.e. commissioning, testing, inspection of work by the electrical inspector, execution of agreement between user authority and distribution Company authority before charging of sub station / Line and handed over the work to the *distribution Company. In case of internal electrification, Area illumination and Generator wiring works payment of bill will be made only after completion of the work in all respects i.e. commissioning, testing and handed over the work to the user authority.*
24. All the transit risk shall be responsibility of the contractor.
25. Failure to complete the work in full within the stipulated period may lead to forfeiture of EMD and blacklisting of the contractor/firm.
26. The authorities are not bound to accept the lowest quoted rate.
27. Terms and conditions of this tender document can not be negotiated for variations.
28. The authority reserves the right to reject any or all tender in whole or part without assigning any reason and can impose any other condition(s) as deemed proper before or in course of finalisation of the tender.
29. The approved tender may be cancelled by the authority any time during validity without assigning any reason thereof and no claim can lie against OPHW&C for such cancellation.
30. All materials required for the work should be approved brand of the concerned Distribution company / as per the given specification and brand. Before take up the work A.P.M (Electrical) shall verify/ certify the quality of materials.
31. Before installation of the transformer E&MR certificate shall be submitted along with CPRI certificate and guarantee certificate of the transformer shall be submitted.
32. LT bushing cover and tap changer shall be provided.
33. All the disputes shall be subject to Jurisdiction of Civil Courts situated at Bhubaneswar.

Signature & seal of the Bidder.

**Sd/-
Joint Manager (Elect.)**

GENERAL BID FORM
BID REFERENCE NO: - 02/ 2015-16/ELECT/ OPHWC

1.Name :

Full Address :

Fax No :

Telephone No :

E-mail address of the firm :

2.Legal Status of the firm :

3.Give the location and Address of your Office/ Branch office :

4.Kindly confirm by writing” Yes” of “No” only

[A] Have you enclosed the EMD? If yes, mention the amount and its identifying details.

[B] Have you enclosed the valid H.T./ M.V. License?

[C] Have you enclosed the VAT clearance certificate?

[D] Have you enclosed the PAN card?

[E] Have you enclosed the audited balance sheet?

[F] Copies of assessment return of sales tax and income tax of last three years.

[G] Have you enclosed all the documents and papers called for in this tender document?

Kindly enclose a list. (Use a separate sheet of paper)

[H] If the answer to [G] above is ‘No’, which of the Documents / papers called for in the tender document have not enclosed.

(Kindly enclose a list of such document/papers – Use separate Sheet of paper, if necessary)

Signature & seal of the Bidder.

Sd/-
Joint Manager (Elect.)

OFFICE OF THE CHAIRMAN-CUM- MANAGING DIRECTOR.

ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD., BHUBANESWAR.

BILL OF QUANTITY

TENDER NO.- 02/2015-16/ ELECT/OPHWC

NAME OF THE WORK :- EXECUTION OF INTERNAL ELECTRIFICATION WORKS OF SUB-JAIL,BANPUR IN THE DIST. OF KHURDA.

Sl. No.	SCOPE OF WORK	UNIT	RATE	QUOTED RATE INCLUSIVE OF ALL IN RS.	QUOTED AMOUNT INCLUSIVE OF ALL IN RS.
---------	---------------	------	------	-------------------------------------	---------------------------------------

A ADMINISTRATIVE BUILDING

1	Semi Concealed wiring to different points with ISI marked 1.5 sq.mm(current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm.dia. Extra super quality polythene/ pvc pipe including supply & fixing of 6A, 250V. flush type switch mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose / angle holder etc. mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. (a)Switch, ceiling rose, angle holder, bell push switch, batten holder etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]				
(a)	Angle Holder Point	Nos	1		
(b)	Secondary Light Point	Nos	4		
(c)	Siren Point	Nos	1		
(d)	Call Bell Point	Nos	2		

2	<p>Semi Concealed wiring to Computer point with ISI marked 1.5sq.mm(3/20SWG) (current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core unsheathed copper conductor in 19 mm. dia. super quality polythene/ pvc pipe including supply & fixing of 3 nos of 6A, 250V. flush type socket & 3 nos of switch mounted on 3 mm. thick bakelite cover on required size iron board /existing board duly painted & fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 7 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity copper wire including all connections as per instruction of Electrical Engineer-in- charge.All switches & ceiling roses are ISI marked. [Make- (a)Switch,socket etc– Anchor Roma/legrand/ Havells Crabtree ,(b) Wires -Finolex/RR/Great White/HPL/HAVELLS , (c) all other materials ISI mark]</p>	Nos	1		
3	<p>Semi Concealed wiring to 5 pin 6 Amp. socket point with ISI marked 1.5 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/ pvc pipe including supply & fixing of 5 pin 6 Amp. 250V. flush type socket & switch mounted on 3 mm. thick bakelite cover on required size iron board / existing board duly painted & fixed inside/on the wall with 1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge. [Make- (a)Switch,Socket etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	16		

4	Semi Concealed wiring to power point [16 Amp.] with ISI marked 6.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/ pvc pipe including supply & fixing of 5 pin 16 Amp. 250V. flush type socket, switch, separate/ combine) mounted on 3 mm.thick bakelite cover on required size iron board duly painted & fixed inside/on the wall with 1.5 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge.[Make- (a)Switch,socket etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/ HAVELLS (c) all other materials ISI mark]	Nos	1		
5	Semi Concealed wiring to submain with two runs of ISI marked 1.5 sq.mm , 650 / 1100 volt. Pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc /polythene pipe with 1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire from BDB's [L] to switch boards and separate 5 Amp.socket points including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]	Mtr	45		
6	Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]	Nos	10		
7	Supply and fixing of calling bell (ding dong) including all accessories and connections as per instruction of Electrical Engineer-in-charge.	Nos	2		

8	Supply and fixing of 1 x 28 wt. T5 patty type tube light fittings complete set with lamp , connecting wire and all accessories refer to catalouge No - MAKE – CROMPTON CODE – T5GP28EB/MAKE-PHILIPS MODEL-MIROLTA SLIM-CODE-TMS540/MAKE-HPL-CODE-HIBE10128 including fixing and connections as per instruction of Electrical Engineer-in-charge..	Nos	32		
9	Supply and fixing of 1200 mm sweep AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - [MAKE- USHA ,MODEL-ATOM , /CROMPTON,MODEL-EMPOWER 50 /KHAITAN MODEL – NEWTECetc. including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	26		
10	Supply & Fixing of electrically operated , double mounted type single phase 200/250 volt 6000 RPM 50 Hz , 3 mile range siren including supply of all materials and construction of siren shed & siren base	No	1		
11	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No- CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	3		
12	Supply and installation of 1.5Tr. Split type Air Conditioner (5 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER KURVE, /MAKE – BLUE STAR, CODE-3HW18TB , MAKE OF STABILIZER-JYOTI/SHAKTI/ AUTOTEK	Nos	1		

13	Supply and fixing of 400 mm wall mounted fan with all accessories refer to catalouge No - KHAITAN MODELMERLIN 1/./MAKE-USHA/MODEL-MIST AIR ULTRA/MAKE CROMPTON/MODEL-WM HIGH FLO WAVE. etc. including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	2		
14	Supply & Fixing of angle holder/batten holder(Make- Anchor Penta)	Nos	11		
15	Supply & Fixing of Ceiling rose(Make- Anchor Penta)	Nos	1		
16	Supply and fixing of 25Amp. rotary Double pole main switch with 32 Amp. Cut out including all accessories and connections.[Make-(a)Main Switch - Simens/HPL/L&T /ABB, (b)Cut out- Anchor/BPL, © Volt meter, Ammeter- AE/CAPPA, (d) all other accessories ISI mark].	Nos	2		
17	Supply & Fixing of 6A switch & removing of Old Switchesr(Make- Anchor Penta)	Nos	97		
18	Supply & Fixing of Electronic step regulatorr(Make- Anchor Penta)	Nos	32		
19	Supply & Fixing of 11"x13"(B.K Cover) (Make- Royalam / National)	Nos	12		
20	Supply & Fixing of 9"x11" (B.K Cover)(Make- Royalam / National)	Nos	6		
21	Supply & Fixing of 9"x7" (B.K Cover)(Make- Royalam / National)	Nos	2		
22	Supply & Fixing of 7"x5" (B.K Cover)(Make- Royalam / National)	Nos	2		
23	MainDistribution Board :-				

Supply, delivery, installation, testing & commissioning of L.T. indoor floor/ wall mounted type distribution boards made out of 2 mm thick CR sheet metal cubicle fixed on m.s. channel base, duly acid treated for derusting, primed and painted with 2 coats of powder coating of approved shade; dust, damp & vermin proof ; having hinged door and compartmental arrangement for each equipment & busbar chamber on the top of the panel running horizontally; having provision for cable/ conduit entry, earthing studs as per specification mentioned below duly factory wired conforming to the relevant ISS and as per special conditions of contract making good the damages caused complete as per the direction of Electrical Engineer-in-Charge ..[Make-(a)MCB /MCCB - Legrand/ Schnider/L&T/ ABB, (b)Volt meter, Ammeter-AE/CAPPA, (d) all other accessories ISI mark]

Incoming:

1 no. 200 A, 35 kA, FP MCCB

Outgoing:

Busbar : 4 Nos 250 A , 500V Electrolytic copper strips

125 AMP. 4 POLE CHANGE OVER PANEL
- 1 No

Outgoing:

Busbar : 4 Nos150A, 500V Electrolytic copper strips

63 AMP 4P MCB - 3 SET WITH STUD CONNECTOR

63 AMP DP MCB - 3 SET WITH STUD CONNECTOR

32 AMP DP MCB - 3 SET WITH STUD CONNECTOR

Instruments:

1 no of 0-200A amperemeter with cts with selector switch

1 no of 0-500v voltmeter with selector switch

1set: LED type R-Y-B phase indicating lamps with control fuses

1.0

Set

B HOSPITAL

1	Semi Concealed wiring to different points with ISI marked 1.5 sq.mm(current carrying capcity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm.dia. Extra super quality polythene/ pvc pipe including supply & fixing of 6A, 250V. flush type switch mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose / angle holder etc. mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Switch, ceiling rose, angle holder, bell push switch, batten holder etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]				
(a)	Angle Holder Point	Nos	1		

2	<p>Semi Concealed wiring to Security light point at 18' height from ground level/ top corners of the building with ISI marked 1.5 sq.mm,(current carrying capacity min. 13 Amps.) 650/1100 volt. pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/ pvc pipe including supply & fixing of 6 Amp. / 16 Amp. ,250V. flush type switch mounted on 3 mm.thick bakelite cover on required size iron board duly painted & fixed at ground floor lobby inside/on the wall including supply of ceiling rose mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. All switches & ceiling roses are ISI marked.[Make- (a)Switch, ceiling rose etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	1		
---	--	-----	---	--	--

3	<p>Semi Concealed wiring to ceiling fan point with ISI marked 1.5 sq.mm(current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/pvc pipe including supply & fixing of 6A,250V. flush type switch with step type electronic regulator mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm (current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge. [Make- (a)Switch, ceiling rose etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	1		
4	<p>Semi Concealed wiring to submain with two runs of ISI marked 1.5 sq.mm , 650 / 1100 volt. Pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc /polythene pipe with 1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire from BDB's [L] to switch boards and separate 5 Amp.socket points including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Mtr	40		
5	<p>Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]</p>	Nos	8		

6	Supply and fixing of 1 x 28 wt. T5 patty type tube light fittings complete set with lamp , connecting wire and all accessories refer to catalouge No - MAKE – CROMPTON CODE – T5GP28EB/MAKE-PHILIPS MODEL-MIROLTA SLIM-CODE-TMS540/MAKE-HPL-CODE-HIBE10128 including fixing and connections as per instruction of Electrical Engineer-in-charge..	Nos	11		
7	Supply and fixing of 900 mm sweep AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - KHAITAN, MODEL – MAGNET/ MAKE-USHA MODEL-SPIN/MAKE-CROMPTONMODEL-BRIZAIR including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	1		
8	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No-CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	1		
9	Supply & Fixing of Electronic step regulator(Make- Anchor Penta)	Nos	7		
10	Supply & Fixing of Angle Holder (Make-Anchor Penta)	Nos	8		
11	Supply & Fixing of 6A switch (Make- Anchor Penta)	Nos	30		
12	Supply & Fixing of 6A Socket (Make- Anchor Penta)	Nos	6		
13	Supply & Fixing of 11"x13"(B.K Cover) (Make- Royalam / National)	Nos	5		
14	Supply & Fixing of 9"x7" (B.K Cover) (Make-Royalam / National)	Nos	1		

SUB TOTAL -B

-

C KITCHEN AND DINING

1	<p>Semi Concealed wiring to Security light point at 18' height from ground level/ top corners of the building with ISI marked 1.5 sq.mm,(current carrying capacity min. 13 Amps.) 650/1100 volt. pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc / polythene pipe including supply & fixing of 6 Amp. / 16 Amp. ,250V. flush type switch mounted on 3 mm.thick bakelite cover on required size iron board duly painted & fixed at ground floor lobby inside/on the wall including supply of ceiling rose mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Switch, ceiling rose etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	1		
---	--	-----	---	--	--

2	<p>Semi Concealed wiring to ceiling fan point with ISI marked 1.5 sq.mm(current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc / polythene pipe including supply & fixing of 6A,250V. flush type switch with step type electronic regulator mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm (current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge. [Make- (a)Switch, ceiling rose etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	1		
3	<p>Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]</p>	Nos	3		
4	<p>Supply and fixing of 1 x 28 wt. T5 patty type tube light fittings complete set with lamp , connecting wire and all accessories refer to catalouge No - MAKE – CROMPTON CODE – T5GP28EB/MAKE-PHILIPS MODEL-MIROLTA SLIM-CODE-TMS540/MAKE-HPL-CODE-HIBE10128 including fixing and connections as per instruction of Electrical Engineer-in-charge..</p>	Nos	15		
5	<p>Supply and fixing of 1200 mm sweep AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - [MAKE- USHA ,MODEL-ATOM , /CROMPTON,MODEL-EMPOWER 50 /KHAITAN MODEL – NEWTECetc. including hanging and connections as per instruction of Electrical Engineer-in-charge.</p>	Nos	1		

6	Supply and fixing of 1400 mm sweep(56") AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - [MAKE- USHA ,MODEL-ATOM , /CROMPTON,MODEL-EMPOWER 50 /KHAITAN MODEL – NEWTECetc. including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	9		
7	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No-CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	1		
8	Supply & Fixing of 6A switch (Make- Anchor Penta)	Nos	34		
9	Supply & Fixing of 6A Socket(Make- Anchor Penta)	Nos	5		
10	Supply & Fixing of 11"x13" (B.K Cover)(Make- Royalam / National)	Nos	6		
		SUB TOTAL -C			-
D	MALE WARD				

1	<p>Semi Concealed wiring to different points with ISI marked 1.5 sq.mm(current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm.dia. Extra super quality polythene/ pvc pipe including supply & fixing of 6A, 250V. flush type switch mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose / angle holder etc. mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Switch, ceiling rose, angle holder, bell push switch, batten holder etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>				
a	Angle Holder Point	Nos	12		
b	TV Point	Nos	8		
2	<p>Semi Concealed wiring to 5 pin 6 Amp. socket point with ISI marked 1.5 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/ pvc pipe including supply & fixing of 5 pin 6 Amp. 250V. flush type socket & switch mounted on 3 mm. thick bakelite cover on required size iron board / existing board duly painted & fixed inside/on the wall with1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge. [Make- (a)Switch ,socket etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	16		

3	Semi Concealed wiring to submain with two runs of ISI marked 4.0 sq.mm , 650 / 1100 volt. Pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc /polythene pipe with 1.5 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire from Main Switch to B.D.B. -2 including all connections as per instruction of Electrical Engineer-in-charge.[Make- (a)Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]	Mtr	30		
4	Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]	Nos	53		
5	Supply and fixing of 1 x 28 wt. T5 patty type tube light fittings complete set with lamp , connecting wire and all accessories refer to catalouge No - MAKE – CROMPTON CODE – T5GP28EB/MAKE-PHILIPS MODEL-MIROLTA SLIM-CODE-TMS540/MAKE-HPL-CODE-HIBE10128 including fixing and connections as per instruction of Electrical Engineer-in-charge..	Nos	66		
6	Supply and fixing of 1400 mm sweep AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - [MAKE- USHA ,MODEL-ATOM , /CROMPTON,MODEL-EMPOWER 50 /KHAITAN MODEL – NEWTECetc. including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	64		
7	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No-CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	2		
8	Supply & Fixing of step type electronic regulator(Make- Anchor Penta)	Nos	64		

9	Supply & Fixing of angle holder (Make-Anchor Penta)	Nos	41		
10	Supply & Fixing of 6A Switch (Make-Anchor Penta)	Nos	198		
11	Supply & Fixing of 6A socket (Make- Anchor Penta)	Nos	1		
12	Supply & Fixing 40 mm GI pipe	RFT	20		
13	Fixing of starter panel	Nos	1		
14	Supply and fixing of 16 Amp. DPMCB with PVC Encloser with 32 Amp. Cut out including all accessories and connections.[Make-(a)Main Switch - Simens/HPL/L&T/ABB, (b)Cut out-Anchor/BPL, © Volt meter, Ammeter-AE/CAPPA, (d) all other accessories ISI mark].	Nos	1		
15	Fixing of 11"x13" (B.K Cover)(Make-Royalam / National)	Nos	33		
		SUB TOTAL -D			-
E	TOILET BLOCK				
1	Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]	Nos	20		
2	Supply & Fixing of 6A switch (Make -Anchor Penta)	Nos	24		
3	5/9 watt. CFL (Make- Crompton/ Philips)	Nos	4		
4	Supply & Fixing of Angle Holder (Make-Anchor Penta)	Nos	20		
		SUB TOTAL -E			-
F	FEMALE WARD				

1	<p>Semi Concealed wiring to different points with ISI marked 1.5 sq.mm(current carrying capacity min. 13 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm.dia. Extra super quality polythene/ pvc pipe including supply & fixing of 6A, 250V. flush type switch mounted on 3 mm. thick bakelite cover on required size iron board duly painted & fixed inside/on the wall including supply of ceiling rose / angle holder etc. mounted on 3 mm. thick bakelite cover on appropriate size iron board duly painted or RJ box (ceiling) fixed inside/on the wall with 1.0 sq.mm(current carrying capacity min. 11 Amps.) 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Switch, ceiling rose, angle holder, bell push switch, batten holder etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>				
(a)	TV Point	Nos	2		
(b)	Call Bell Point	Nos	1		
2	<p>Semi Concealed wiring to 5 pin 6 Amp. socket point with ISI marked 1.5 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality polythene/ pvc pipe including supply & fixing of 5 pin 6 Amp. 250V. flush type socket & switch mounted on 3 mm. thick bakelite cover on required size iron board / existing board duly painted & fixed inside/on the wall with1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire including all connections as per instruction of Electrical Engineer-in-charge. [Make- (a)Switch , Socket etc– Anchor Deluxe/ Anchor Penta/Great White /HPL ,(b) Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]</p>	Nos	4		

3	Semi Concealed wiring to submain with two runs of ISI marked 1.5 sq.mm , 650 / 1100 volt. Pvc insulated single core (stranded) unsheathed copper conductor in 19 mm. dia. extra super quality pvc /polythene pipe with 1.0 sq.mm 650/1100 volt pvc insulated single core (stranded) unsheathed copper conductor as earth continuity wire from BDB's [L] to switch boards and separate 5 Amp.socket points including all connections as per instruction of Electrical Engineer-in- charge. [Make- (a)Wires - Finolex/RR/Great White/HPL/HAVELLS (c) all other materials ISI mark]	Mtr	45		
4	Supply and fixing of 18 watt. holder type CFL lamp for the installed angle holder .[Make-CG/Philips/Bajaj]	Nos	53		
5	Supply and fixing of calling bell (ding dong) including all accessories and connections as per instruction of Electrical Engineer-in-charge.	Nos	1		
6	Supply and fixing of 1 x 28 wt. T5 patty type tube light fittings complete set with lamp , connecting wire and all accessories refer to catalouge No - MAKE – CROMPTON CODE – T5GP28EB/MAKE-PHILIPS MODEL-MIROLTA SLIM-CODE-TMS540/MAKE-HPL-CODE-HIBE10128 including fixing and connections as per instruction of Electrical Engineer-in-charge..	Nos	12		
7	Supply and fixing of 1200 mm sweep AC ceiling fan with star 5 rated connecting wire and all accessories refer to catalouge No - [MAKE- USHA ,MODEL-ATOM , /CROMPTON,MODEL-EMPOWER 50 /KHAITAN MODEL – NEWTECetc. including hanging and connections as per instruction of Electrical Engineer-in-charge.	Nos	20		
8	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No-CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	2		
9	Supply & Fixing of angle holder/batten holder (Make- Anchor Penta)	Nos	53		

10	Supply & Fixing of 6A Socket (Make- Anchor Penta)	Nos	2		
11	Supply & Fixing of Electronic Regulator(Make- Anchor Penta)	Nos	20		
12	Supply & Fixing of 6A Switch (Make- Anchor Penta)	Nos	84		
13	Supply & Fixing of 11"x13"(B.K Cover) (Make- Royalam / National)	Nos	10		
14	Supply & Fixing of 9"x7" (B.K Cover) (Make- Royalam / National)	Nos	3		
			SUB TOTAL -F		-
G OUTSIDE LIGHTING					
1	Supply & fixing of 4 x24 wt. T5 energy saving light fitting with bulb,choke,cover, G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No-CROMPTON CODE – T5SHO424 EB IP 65/MAKE-HPL-CODE-HPLT5STAL424 / PHILIPSincluding fixing and connections as per instruction of Electrical Engineer-in-charge.	Nos	16		
2	Supply,laying & testing of 2core,16 sq.mm PVC insulated , PVC sheathed aluminium armoured power cable of 1100 volt grade through under ground / surface as per the site requirement including all accessories and connections with making good the damages caused and as per direction of Engineer-in-charge Board...[Make- (a) Cable - Finolex//Havells (c) all other materials ISI mark]	Mtr.	120		
3	Supply and fixing of out door type 63 Amp. rotary double pole main switch 63 Amp. cut out including all accessories Connections. [Make- (a)Main Switch - Simens/HPL/L&T /ABB, (b)Cut out- Anchor/BPL, (c) Volt meter, Ammeter-AE/CAPPA, (d) all other accessories ISI mark]	Set	1		
4	Construction of 1 phase 2 wire L.T line with (1 x 35 + 1 x 16) AB cable with 8 mtr. long 200kg PSC Pole including concreting & coupling.	Km	0.35		
5	Supply and Fixing 40 mm GI pipe	Mtr	21		

Seal & Signature of the Contractor

Sd/-
Asst. Project Manager (Elect.)