

Tender Inviting Authority: JOINT MANAGER [ELECTRICAL DIVISION] ,  
THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD,

Name of work :-REPAIR & RENOVATION OF INTERNAL ELECTRIFICATION WORKS AND AREA ILLUMINATION WORKS AT  
DISTRICT JAIL PHULBANI IN THE DISTRICT OF KANDHAMAL

Contract No: BID REF NO.- 17 /JM/ ELECT/OPHWC/2020-21

Bidder  
Name

**SCHEDULE OF WORKS**

Sl. No.	Description of work	Qty.	Unit	Estimated Rate	AMOUNT Rs.
A	<b>Adminstrative Building (Superintendent Chamber)</b>				
1	Recessed wiring to Ceiling light point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	4	No.	862.51	3450.04
2	Recessed wiring to Exhaust fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	862.51	862.51

3	Point wiring for 15/16 amp socket (FOR AC)outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch/Socket- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	5	No.	579.13	2895.65
4	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistarnd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	40	Mtr	183.35	7334.00
5	Recessed wiring to submain in 2 x 2.5 sqmm FR PVC insulated single core multistarnd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 1.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L <(>&<)>T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.2)	75	Mtr	136.98	10273.50
6	Recessed wiring to submain in 2 x 4 sqmm FR PVC insulated single core multistarnd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 1.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required from BDB to Power point(Make of wire Finolex / L &T / Anchor / Havels/ V guard)	40	Mtr	153.8	6152.00
7	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	120.75	362.25

8	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	1	No.	1874.17	1874.17
9	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	2	Nos.	758.99	1517.98
10	Supply and fixing of 300 mm sweep exhaust fan with connecting wire and all accessories including fixing and connections as per instruction of Electrical Engineer-in-charge. - [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	1	No.	2024	2024.00
11	Supply and fixing of 15 wt. LED Down lighter on False ceiling with comprises of aluminium die cast housing finished in white powder coated & ABS white ring . The downlighter is pre-wired with high efficiency electronic driver. High traslucent frosted diffuser is used to get glare free, smooth light distribution. Operating Voltage Range : 150V~ - 270V, PF : > 0.9, 100 Lum/Watt with lamp , choke, connecting wire, and all accessories and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	6	Nos.	1201.75	7210.50
12	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER- JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10
13	Supply and fixing of 16 Amp Top (for inverter installation)with all accessories and connections as per instruction of Electrical Engineer-in-charge	2	Nos	80.5	161.00
14	Supply and fixing of inverter 1050 VA Sine wave Inverter with 12 volt 150 AH Battery including stand with all accessories and connections as per instruction of Electrical Engineer-In-Charge(Make- MICROTEK/LUMINOUS)	2	Nos	21050	42100.00

15	Supply and fixing of 300 mm sweep exhaust fan with connecting wire and all accessories including fixing and connections as per instruction of Electrical Engineer-in-charge. - [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	1	Nos.	2024	2024.00
<b>B</b>	<b>Administrative Building (Computer Room )</b>				0.00
1	Recessed wiring to Angle holder point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	853.66	853.66
2	Point wiring for 15/16 amp socket outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	No.	579.13	1158.26
3	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistard copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No- 1.8.4)	45	Mtr	183.77	8269.65
4	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	120.75	362.25

5	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE-KHAITAN/USHA/ CROMPTON GREAVES)	3	No.	1874.17	5622.51
6	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	758.99	2276.97
7	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER-JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10
<b>C</b>	<b>Administrative Building (Sub Jailer Room )</b>				0.00
1	Recessed wiring to Angle holder point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	853.66	853.66
2	Point wiring for 15/16 amp socket outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	579.13	579.13

3	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	45	Mtr	183.89	8275.05
4	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	120.75	362.25
5	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	2	Nos.	1874.17	3748.34
6	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	758.99	2276.97
7	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER- JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10
<b>D</b>	<b>Administrative Building (Office Room)</b>				0.00
1	Recessed wiring to Angle holder point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	No.	853.66	1707.32

2	<p>Recessed wiring to Tube Light Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp; T / Anchor / Havels/ V guard,HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	4	Nos.	862.51	3450.04
3	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L &amp; T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	1	No.	862.51	862.51
4	<p>Point wiring for 5/ 6 amp socket outlet (for wall fan)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch &amp; socket , phenolic laminated sheet suitable size ISI marked MS Box &amp; earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	2	Nos.	406.12	812.24

5	Point wiring for 15/16 amp socket outlet (AC Point)with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	No.	579.13	1158.26
6	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	40	Mtr	183.77	7350.80
7	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	120.75	483.00
8	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE-KHAITAN/USHA/ CROMPTON GREAVES)	3	Nos.	1874.17	5622.51
9	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	3	Nos.	758.99	2276.97
10	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER-JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10



11	Supply & fixing of 400MM (16") WALL MOUNTED FAN WITH COMPLETE ACCESSORIES[BROWN/WHITE].including hanging and connections as per instruction of Electrical Engineer-in-charge[MAKE-KHAITAN/USHA/CROMPTON GREAVES)	2	Nos.	2127.5	4255.00
E	<b>Administrative Building (Welfare Office &amp; Interview &amp; Entrance )</b>				0.00
1	Recessed wiring to Angle holder point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	Nos.	853.66	2560.98
2	Recessed wiring to Tube light point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	Nos.	862.51	1725.02

3	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	2	Nos.	862.51	1725.02
4	<p>Recessed wiring to Security Light Point(4X24WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20mm dia non metallic PVC flexible conduit with 20 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	1	Nos.	862.51	862.51
5	<p>Point wiring for 5/ 6 amp socket outlet ( Separate) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch socket , phenolic laminated sheet suitable size ISI marked MS Box earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)</p>	2	Nos.	406.12	812.24

6	Point wiring for 15/16 amp socket outlet (AC Point)with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	579.13	579.13
7	Recessed wiring to Portico light Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	826.51	826.51
8	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistarnd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	40	Mtr	183.77	7350.80
9	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	9	Nos.	120.75	1086.75
10	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	6	Nos.	1874.17	11245.02

11	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	9	Nos.	758.99	6830.91
12	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER- JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10
13	Supply and fixing of SURFACE MOUNTED LED 12 W SQUARE/ROUND PORTICO LIGHT WITH POWDER COATED FINISHED IN WHITE HOUSING 1with lamp , choke,connecting wire, and all accessories and connections as per instruction of Electrical Engineer-in-charge.( Make- CROMPTON/ PHILIPS/WIPRO)	1	No.	1322.5	1322.50
14	Supply & fixing of 90 Wt. LED Street light fitting comprises of Pressure die cast Aluminium housing powder coated in silver grey and toughened glass, Surge Arrester 1 No & 100lum/wt, Protection IP66 with bulb,choke,cover,G.I bracket,clamp & nut bolt connecting wire all accessories ( Make- CROMPTON/ PHILIPS/ WIPRO)	1	No.	10376.45	10376.45
15	Supply & fixing of 400MM (16") WALL MOUNTED FAN WITH COMPLETE ACCESSORIES[BROWN/WHITE].including hanging and connections as per instruction of Electrical Engineer-in-charge[MAKE- KHAITAN/USHA/CROMPTON GREAVES)	1	No.	2127.5	2127.50
<b>F</b>	<b>Administrative Building (Main Enterance )</b>				0.00
1	Recessed wiring to Siren point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L & T / Anchor / Havells/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	Nos.	853.66	853.66

2	Supply and fixing of Electrically operated double mounted type single phase 200/250 volt ,6000 rpm, 50 Hz, 3 mile range Siren ect. Including all accessories all accessories including hanging and connection as per instruction of Electrical Engineer-in-charge	1	Nos.	21620	21620.00
<b>G</b>	<b>Inside Staff Room</b>				0.00
1	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	120.75	483.00
2	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	758.99	3035.96
<b>H</b>	<b>Ward No:- 5</b>				0.00
1	Recessed wiring to Angle holder point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	Nos.	853.66	2560.98
2	Recessed wiring to Tube light point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	5	Nos.	862.51	4312.55

3	Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)	6	Nos.	862.51	5175.06
4	Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	Nos.	862.51	862.51
5	Point wiring for 5/ 6 amp socket outlet (for TV)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)	2	No.	406.12	812.24
6	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	18	Nos.	120.75	2173.50
7	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	20	Nos.	1874.17	37483.40

8	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	22	Nos.	758.99	16697.78
9	Supply <(>&<)> fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp <(>&<)> Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S <(>&<)> HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	14	Nos.	5037	70518.00
1	<b>Kitchen</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	5	Nos.	853.66	4268.30
2	Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	5	Nos.	862.51	4312.55

3	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	1	Nos.	862.51	862.51
4	<p>Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	6	Nos.	862.51	5175.06
5	<p>Point wiring for 5/ 6 amp socket outlet (for GRINDER)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch &amp; socket , phenolic laminated sheet suitable size ISI marked MS Box &amp; earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	2	No.	406.12	812.24



6	Point wiring for 15/16 amp socket outlet (AC Point)with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)	1	No.	579.13	579.13
7	Recessed wiring to Exhaust fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	6	Nos.	826.51	4959.06
8	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistarmd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L & T /Anchor / Havels/ V guard) ( CSR SL .No- 1.8.4)	45	Mtr	183.77	8269.65
9	Supply and fixing of 8 way BDB consists of 32 Amp DP MCB - 1 No and 10 Amp SP MCB -6 Nos.including all accesseries and connection as per instruction of Electrical Engineer-in-charge	1	No.	2734.23	2734.23
10	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	6	Nos.	120.75	724.50
11	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	1	Nos.	1874.17	1874.17

12	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	7	Nos.	758.99	5312.93
13	Supply <(>&<)> fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp <(>&<)> Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S <(>&<)> HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	8	Nos.	5037	40296.00
14	Supply and fixing of 8 way , Double Door MCB Box with 1 No 32 Amp. DPMCB <(>&<)> 6 Nos of 20 Amp. SPMCB with sheet steel encloser ,distribution board, on surface/ recess, complete with tinned copper bus bar , neutral bus bar, earth bar, din bar , detachable gland plate,interconnection , phosphate and power painted including earthing etc as required.( Sl. No- 2.3.6,2.7, )	1	No.	2734.23	2734.23
15	Supply and fixing of 300 mm sweep exhaust fan with connecting wire and all accessories including fixing and connections as per instruction of Electrical Engineer-in-charge. - [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	6	Nos.	2024	12144.00
<b>J</b>	<b>Hospital</b>				0.00
1	Point wiring for 5/ 6 amp socket outlet (for GRINDER)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	Nos.	406.12	812.24

2	Point wiring for 15/16 amp socket outlet (AC Point)with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	579.13	579.13
3	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No- 1.8.4)	55	Mtr	183.77	10107.35
4	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	7	Nos.	120.75	845.25
5	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	1	Nos.	1874.17	1874.17
6	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	758.99	3035.96
7	Supply <(>&<)> fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp <(>&<)> Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S <(>&<)> HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	1	Nos.	5037	5037.00

8	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER-JYOTI/SHAKTI/ AUTOTEK	1	No.	47840.1	47840.10
9	Supply &fixing of 400MM (16") WALL MOUNTED FAN WITH COMPLETE ACCESSORIES[BROWN/WHITE].including hanging and connections as per instruction of Electrical Engineer-in-charge[MAKE-KHAITAN/USHA/CROMPTON GREAVES)	2	Nos.	2127.5	4255.00
K	<b>Ward No 7 &amp; 8</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)	6	Nos.	853.66	5121.96
2	Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)	8	Nos.	826.51	6612.08

3	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	18	Nos.	826.51	14877.18
4	<p>Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	3	Nos.	826.51	2479.53
5	<p>Point wiring for 5/ 6 amp socket outlet (for GRINDER)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch &amp; socket , phenolic laminated sheet suitable size ISI marked MS Box &amp; earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	1	No.	406.12	406.12

6	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L & T / Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	60	Mtr	183.8	11028.00
7	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	15	Nos.	120.75	1811.25
8	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	13	Nos.	1874.17	24364.21
9	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge. ( Make- CROMPTON/ PHILIPS/ WIPRO)	17	Nos.	758.99	12902.83
10	Supply & fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalogue No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S & HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	8	Nos.	5037	40296.00
11	Supply and fixing of 8 way , Double Door MCB Box with 1 No 32 Amp. DPMCB & 6 Nos of 20 Amp. SPMCB with sheet steel encloser ,distribution board, on surface/ recess, complete with tinned copper bus bar , neutral bus bar, earth bar, din bar , detachable gland plate,interconnection , phosphate and power painted including earthing etc as required.( Sl. No- 2.3.6,2.7, )	1	No.	2734.23	2734.23
<b>L</b>	<b>Ward No 1 &amp; 2</b>				0.00

1	<p>Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	2	No.	853.66	1707.32
2	<p>Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)</p>	3	Nos.	862.51	2587.53
3	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	3	Nos.	862.51	2587.53

4	<p>Recessed wiring to Security Light Point (IX36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	1	No.	862.51	862.51
5	<p>Point wiring for 5/ 6 amp socket outlet (forTV)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch &amp; socket , phenolic laminated sheet suitable size ISI marked MS Box &amp; earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	1	No.	406.12	406.12
6	<p>Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistarnd copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &amp;T /Anchor / Havels/ V guard) ( CSR SL .No- 1.8.4)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	35	Mtr	183.77	6431.95



7	Point wiring for 15/16 amp socket outlet (AC Point)with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	579.13	579.13
8	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	8	Nos.	120.75	966.00
9	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	7	Nos.	1874.17	13119.19
10	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	8	Nos.	758.99	6071.92
11	Supply <(>&<)> fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp <(>&<)> Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S <(>&<)> HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	5	Nos.	5037	25185.00
12	Supply and installation of 1.5Tr. Split type Air Conditioner ( 3 Star) of reputed brand with supply and fixing of 5 KVA ,130-280 Volt voltage range wall/floor mounted stabiliser including all accessories,fastner angle copper piping up to 15ft & connections as per instruction of Electrical Engineer-in-charge MAKE of A.C. – CARRIER /MAKE – BLUE STAR, , MAKE OF STABILIZER- JYOTI/SHAKTI/ AUTOTEK	1	No.	47840	47840.00

M	<b>Ward No 3</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	4	Nos.	853.66	3414.64
2	Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	6	Nos.	862.51	5175.06
3	Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	No.	863.65	2590.95

4	Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	No.	862.51	2587.53
5	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	10	Nos.	120.75	1207.50
6	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	8	Nos.	1874.17	14993.36
7	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	10	Nos.	758.99	7589.90
8	Supply & fixing of 45 Wt. LED Street light fitting comprises of Pressure die cast Aluminium housing powder coated in silver grey and toughened glass, Surge Arrester 1 No & 100lum/wt, Protection IP66 with bulb,choke,cover,G.I bracket,clamp & nut bolt connecting wire all accessories ( Make- CROMPTON/ PHILIPS/ WIPRO)	6	Nos.	5037.00	30222.00
N	<b>Cell Two Nos.</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	Nos.	853.66	1707.32

2	Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	2	Nos.	862.51	1725.02
3	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	2	Nos.	120.75	241.50
4	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	5	Nos.	758.99	3794.95
5	Supply <(>&<)> fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp <(>&<)> Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S <(>&<)> HPLLED4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	5	Nos.	5037	25185.00
<b>0</b>	<b>Ward No 4 (Female)</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	Nos.	853.66	2560.98

2	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	6	Nos.	862.51	5175.06
3	<p>Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	2	No.	862.71	1725.42
4	<p>Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL) Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	2	No.	862.51	1725.02
5	<p>Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make-CROMPTON/ PHILIPS/ WIPRO)</p>	10	Nos.	120.75	1207.50

6	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE-KHAITAN/USHA/ CROMPTON GREAVES)	8	Nos.	1874.78	14998.24
7	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	8	Nos.	758.99	6071.92
8	Supply & fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No- MAKE-CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S & HPLLED4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	5	Nos.	5037	25185.00
<b>P</b>	<b>Street Light</b>				0.00
1	Supply & fixing of 90 Wt. LED Street light fitting comprises of Pressure die cast Aluminium housing powder coated in silver grey and toughened glass, Surge Arrester 1 No & 100lum/wt, Protection IP66 with bulb,choke,cover,G.I bracket,clamp & nut bolt connecting wire all accessories ( Make-CROMPTON/ PHILIPS/ WIPRO)	32	Nos.	10376.45	332046.40
2	Supply and fixing of 4.0 sqmm 2 core PVC Aluminium service wire including all accessories and connections.(make-Joshi/Multicab)	120	Mtr	41.63	4995.60
<b>Q</b>	<b>Watch Tower (Four Nos.)</b>				0.00

1	Recessed wiring to Security Light Point(4X24WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 20 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	10	Nos.	863.65	8636.50
2	Recessed wiring to Bulk Head Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . (Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	8	Nos.	865.03	6920.24
3	Point wiring for 5/ 6 amp socket outlet (for GRINDER)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	4	Nos.	406.12	1624.48
4	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	8	Nos.	120.75	966.00

5	Supply and fixing of Bulk Head fitting with 9 wt. LED Bulb including all accessories and connections as per instruction of Electrical Engineer-in-charge.( Make- CROMPTON/ PHILIPS/ WIPRO)	12	Nos.	887.8	10653.60
6	Supply & fixing of 90 Wt. LED Street light fitting comprises of Pressure die cast Aluminium housing powder coated in silver grey and toughened glass, Surge Arrester 1 No & 100lum/wt, Protection IP66 with bulb,choke,cover,G.I bracket,clamp & nut bolt connecting wire all accessories ( Make-CROMPTON/ PHILIPS/ WIPRO)	16	Nos.	10376.45	166023.20
<b>R</b>	<b>Video Conference Hall inside Jail</b>				0.00
1	Repairing mentainance of two nos. A.C. inside the Video Conference Hall (L.S.) as per site requirement.	2	LS	5000.00	10000.00
2	Supply and fixing of 15 wt. LED Down lighter on False ceiling with comprises of aluminium die cast housing finished in white powder coated<(>&<)> ABS white ring . The downlighter is pre-wired with high efficiency electronic driver. High traslucent frosted diffuser is used to get glare free, smooth light distribution. Operating Voltage Range :150V~ - 270V, PF : > 0.9, 100 Lum/Watt with lamp , choke, connecting wire, and all accessories and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	6	Nos.	1201.75	7210.50
<b>S</b>	<b>Barrack inside Jail -1</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	5	Nos.	853.66	4268.30



2	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)</p>	2	Nos.	862.51	1725.02
3	<p>Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	1	No.	863.65	863.65
4	<p>Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL) Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	4	Nos.	862.51	3450.04

5	Point wiring for 5/ 6 amp socket outlet (for GRINDER)with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	6	Nos.	406.12	2436.72
6	CPoint wiring for 15/16 amp socket outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L & T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	No.	579.13	579.13
7	Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	5	Nos.	120.75	603.75
8	Supply & fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No- MAKE-CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S & HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	1	Nos.	5037	5037.00
9	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	8	Nos.	758.99	6071.92

10	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE-KHAITAN/USHA/ CROMPTON GREAVES)	4	Nos.	1874.17	7496.68
11	Supply and laying of 16 sq.mm 2 core PVC Al. Arm Cable of 1.1 KV grade ISI Marked direct in ground including excavation , sand cushioning , protective covering and refilling the trench etc. as required. ( sl no- 5.1.1)(MAKE-FINOLEX/ HAVELLS/ POLYCAB)	90	mtr	254.52	22906.80
<b>T</b>	<b><i>Barrack inside Jail -2</i></b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	Nos.	853.66	2560.98
2	Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	1	Nos.	862.51	862.51

3	<p>Recessed wiring to Security Light Point (IX36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	1	No.	863.28	863.28
4	<p>Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	3	Nos.	862.51	2587.53
5	<p>Point wiring for 5/ 6 amp socket outlet with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch &amp; socket , phenolic laminated sheet suitable size ISI marked MS Box &amp; earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch- ANCHOR/HAVELLS/L&amp;T/LEGRAND/ ABB</p>	6	Nos.	406.12	2436.72

6	<p>CPoint wiring for 15/16 amp socket outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch socket , phenolic laminated sheet suitable size ISI marked MS Box earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	1	No.	579.13	579.13
7	<p>Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L&amp;T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)</p>	15	Mtr	183.77	2756.55
8	<p>Supply and fixing of 9 WT. LED Bulb installred at angle holder/ batten holder. Make-CROMPTON/ PHILIPS/ WIPRO)</p>	5	Nos.	120.75	603.75
9	<p>Supply &amp; fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp &amp; Nut Bolt connecting wire all accessories refer to catalouge No- MAKE-CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S &amp; HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.</p>	1	Nos.	5037	5037.00
10	<p>Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)</p>	8	Nos.	758.99	6071.92
11	<p>Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE-KHAITAN/USHA/ CROMPTON GREAVES)</p>	4	Nos.	1874.17	7496.68

12	Supply and fixing of 8 way , Double Door MCB Box with 1 No 32 Amp. DPMCB <(>&<)> 6 Nos of 20 Amp. SPMCB with sheet steel encloser ,distribution board, on surface/ recess, complete with tinned copper bus bar , neutral bus bar, earth bar, din bar , detachable gland plate,interconnection , phosphate and power painted including earthing etc as required.( Sl. No- 2.3.6,2.7, )	1	No.	2734.23	2734.23
13	Supply and fixing of 63AMP DPMCB-1NO ,63 AMP .240V CUTOOUT-2NOS METER SPACE WITH LOCKING ARRANGEMENT,METER CUT OUT,COPPER BUS BAR <(>&<)> INDICATOR including all accessories and connections As per instruction of electrical engineer -in-charge.[Make-(a)MCB /MCCB - Legrand/ Schnider/L<(>&<)>T/ ABB, ( b)Volt meter, Ammeter-AE/CAPPA, (d) all other accessories ISI mark]	1	No.	9062	9062.00
<b>U</b>	<b>Barrack inside Jail -3</b>				0.00
	<b>New Wiring Point</b>				0.00
1	Recessed wiring to Angle holder <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &T / Anchor / Havels/ V guard/HPL) Make of Switch- ANCHOR/HAVELLS/L&T/LEGRAND/ ABB	3	Nos.	853.66	2560.98

2	<p>Recessed wiring to Ceiling Fan Point with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	2	Nos.	862.51	1725.02
3	<p>Recessed wiring to Security Light Point (1X36WT) with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ Vguard/HPL)Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	4	No.	863.65	3454.60
4	<p>Recessed wiring to Tube light <b>point</b> with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor of ISI marked with 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch ISI marked and ceiling rose ISI marked mounted on MS Box having front bakelight cover of suitable size, MS Box with 1.0 sq. FR PVC insulated single core multistrand copper conductor as earth wire including all accessories and connection as per direction of Engineer in charge . ( Make of wire Finolex / L &amp;T / Anchor / Havels/ V guard/HPL) Make of Switch-ANCHOR/HAVELLS/L&amp;T/LEGRAND/ABB</p>	3	Nos.	862.51	2587.53

5	Point wiring for 5/ 6 amp socket outlet with 1.5 sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)	1	Nos.	406.12	406.12
6	CPoint wiring for 15/16 amp socket outlet with 4.0sq.mm FR PVC insulated single core multistrand copper conductor ISI marked in recess 20 mm dia non metallic PVC flexible conduit with 5 Amp, 250 V piano type switch & socket , phenolic laminated sheet suitable size ISI marked MS Box & earthing Point with 1 x 1.5 sq.mm FR PVC insulated single core multistrand copper conductor for loop earthing etc as required as per direction of Engineer in charge . ( Make of wire Finolex / L&T / Anchor / Havels/ V guard/HPL)	1	No.	579.13	579.13
7	Recessed wiring to submain in 2 x 6 sqmm FR PVC insulated single core multistrand copper conductor of ISI marked confirming to IS-694/1990 in 20 mm dia non metallic heavy duty flexible conduit 1.6 mm thick along with 1 x 2.5 sqmm FR PVC insulated single core multistrand copper conductor as earth wire as required (Make of wire Finolex / L &T /Anchor / Havels/ V guard) ( CSR SL .No-1.8.4)	15	Mtr	183.77	2756.55
8	Supply and fixing of 9 WT. LED Bulb installed at angle holder/ batten holder. Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	120.75	483.00
9	Supply & fixing of 45 W LED STREET LIGHT FITTING on wall with , G.I. Bracket, Clamp & Nut Bolt connecting wire all accessories refer to catalouge No- MAKE- CROMPTON, CODE-LSTO-45-CDL /MAKE-PHILIPS, MODEL-GREEN LINE , CODE-BRP320 / MAKE-HPL, CODE-HPLLEDST4060S & HPLLEDST4560S including fixing and connections as per instruction of Electrical Engineer-in-charge.	4	Nos.	5037	20148.00



10	Supply and fixing of 4 FT 20 W LED Tube light fitting with lamp including fixing and connections as per instruction of Electrical Engineer-in-charge .( Make- CROMPTON/ PHILIPS/ WIPRO)	4	Nos.	758.99	3035.96
11	Supply and fixing of 1200 mm sweep AC ceiling fan (5 star rated ) with connecting wire and all accessories including hanging and connections as per instruction of Electrical Engineer-in-charge.- [MAKE- KHAITAN/USHA/ CROMPTON GREAVES)	4	Nos.	1874.17	7496.68
12	Supply and laying of 16 sq.mm 2 core PVC Al. Arm Cable of 1.1 KV grade ISI Marked direct in ground including excavation , sand cushioning ,protective covering and refilling the trench etc. as required. ( sl no-5.1.1)	50	mtr	254.52	12726.00
13	Supply and fixing of 8 way BDB consists of 32 Amp DP MCB -1 No and 10 Amp SP MCB -6 Nos.including all accessories and connection as per instruction of Electrical Engineer-in-charge	1	No.	2734.23	2734.23
14	Supply and fixing of 63AMP DPMCB-1NO ,63 AMP .240V CUTOUT-2NOS METER SPACE WITH LOCKING ARRANGEMENT,METER CUT OUT,COPPER BUS BAR <(>&<)> INDICATOR including all accessories and connections As per instruction of electrical engineer -in-charge.[Make-(a)MCB /MCCB - Legrand/ Schnider/L<(>&<)>T/ ABB, ( b)Volt meter, Ammeter-AE/CAPPA, (d) all other accessories ISI mark]	1	No.	9062	9062.00
	<b>CESS</b>				<b>18835.09</b>

	Total Rs.				<b>1,902,344.35</b>
	Total Estimated Cost in Figures.				<b>1,902,344.00</b>
EXCESS	<input type="checkbox"/>	LESS	<input type="checkbox"/>	(Please Tick)	_____%
Quoted Amount in Figures.					
Quoted Amount in words					

N.B-The Estimate Cost is Exclusive of G.S.T i:e @ 12%

Signature of Tenderer with seal

**Sd/-**  
**Asst. Project Manager (Elect.)**

**Sd/-**  
**Asst. Project Manager Elect.(Hqr)**

**Sd/-**  
**Joint Manager (Elect.)**