



THE ODISHA STATE POLICE HOUSING & WELFARE CORPORATION LTD.  
JANAPATH, BHOINAGAR, BHUBANESWAR – 22.

**[Electrical Division]**

Ph: 0674-2541545, 2542921, Fax: 0674-2541543

E-mail: [pmelectricalophwc2021@gmail.com](mailto:pmelectricalophwc2021@gmail.com), Website: [www.ophwc.nic.in](http://www.ophwc.nic.in)

BID REFERENCE NO: - 68 /PM / ELECT / OPHWC/2022-23

CORRIGENDUM

In continuation to the Bid Reference No: 68 / PM/ ELECT / OPHWC/ 2022-23 uploaded in the office web site [www.ophwc.nic.in](http://www.ophwc.nic.in) on 15.12.2022, the corrigendum is being issued as stated below. All other terms & conditions remain unchanged.

1. The capacity of Solar PV Module mentioned in the Page No-09 of the DTCN at Sl. No-1 under heading “SOLAR PV MODULES” **may be read as** “The capacity of Solar PV Module must be minimum 335 Wp. and above (Mono/Poly Crystalline)” **in place of** “The modules having capacity between 325Wp to 335Wp (72 cells)”.
2. The Specification of Solar PV Module mentioned in the Price Bid Sl. No-1 under heading schedule of work (Sl. No-1) **may be read as** “Minimum 335 Wp. and above (Mono/Poly Crystalline)” **in place of** “MONOPERC SOLAR PV MODULES MINIMUM 370 Wp (72 CELL).”.

Sd/-  
Project Manager